



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2012 Test Results w/Appendix J Results

Filter Description

Manufacturer		Filter Model			Filter Part Number		
Camfil		30/30 Dual 9			406331-005		
Filter Type		Media Type		Media Color		Media Area (ft²)	
PleatedPanel		Polyester - Mechanical		Green/White		17	
Nominal Size	Actual Size						
HxWxD	Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets	UL Rating	LabFile	CrRef
24x24x2	23 3/8	23 3/8	1 3/4	29	Yes	1481	1481

ASHRAE® 52.2-2012

Time:	9:56:23	Date:	Jan 17, 2017
Test Number:	16206-007_00004487.047.aec		

Test Data	Test Results	Rated Values
AirFlow (cfm)	1969	1970
Nominal Vel (fpm)	492	493
Initial ΔP (inWG)	0.26	0.30

MERV	9	9	@1969cfm
E ₁ (0.3-1.0μm), (%)	7	n/a	
E ₂ (1.0-3.0μm), (%)	45	≥ 35	
E ₃ (3.0-10μm), (%)	92	≥ 75	
Final DP, (inWG)	1.0	1.0	
Arrestance, (%)	93	8	
DHC, (g)	187		

Temp, (F)	75	Test Aerosol	KCI
RH, (%)	49	Loading Dust	ASHRAE

Comments	

ASHRAE® 52.2-2012 w/App J

Time:	14:51:01	Date:	Jan 19, 2017
Test Number:	16206-012-KCL_00004507.047.aec		

Test Data	Test Results	Rated Values
AirFlow (cfm)	1969	1970
Nominal Vel (fpm)	492	493
Initial ΔP (inWG)	0.26	0.30

MERV-A	9A	9A	@1969cfm
E ₁ -A (0.3-1.0μm), (%)	6	n/a	
E ₂ -A (1.0-3.0μm), (%)	41	≥ 35	
E ₃ -A (3.0-10μm), (%)	87	≥ 75	
Final DP, (inWG)	1.0	1.0	
Arrestance-A, (%)	93	8	
DHC-A, (g)	199		

Temp, (F)	75	Test Aerosol	KCI
RH, (%)	48	Loading Dust	ASHRAE

Comments	

Certified Test Per ASHRAE 52.2-2012

Approval:	<i>Don Thornburg</i> Electronic Signature, Original on file
-----------	--



Operator

AA	Particle Counter	Model
	TSI	OPS 3330
Camfil Permission Required for Distribution		


ASHRAE® 52.2-2012 Test Results

Date:	Jan 17, 2017	Test Number:	16206-007_00004487.047.aec
Manufacturer	Camfil	Filter Model	30/30 Dual 9
		Filter Part Number	406331-005

Clean Resistance Table			
cfm	m ³ /s	inWG	Pa
986	0.47	0.08	20
1481	0.70	0.16	40
1966	0.93	0.26	65
2459	1.16	0.39	97



ΔP (inWG)	Dust Fed (g)
0.26	0
0.30	25
0.48	110
0.67	145
0.85	168
1.01	188






ASHRAE® 52.2-2012 Test Results

Date:	Jan 17, 2017			Test Number:			16206-007_00004487.047.aec					
Manufacturer				Filter Model					Filter Part Number			
Camfil				30/30 Dual 9					406331-005			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	2	3	7	14	29	35	47	68	84	92	96	97
Dust Cond PSE	8	10	16	25	43	50	64	83	95	98	100	100
1st Dust Load PSE	16	22	31	46	65	72	84	95	99	100	100	100
2nd Dust Load PSE	19	27	39	57	76	82	90	97	99	100	100	100
3rd Dust Load PSE	21	32	47	66	82	88	94	98	100	100	100	100
4th Dust Load PSE	24	37	53	71	86	90	95	99	100	100	100	100
Composite Min PSE	2	3	7	14	29	35	47	68	84	92	96	97

Particle Size Efficiency




All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.


ASHRAE® 52.2-2012 Test Results w/ Appendix J Results

Date:	01/19/2017	Test Number:	16206-012-KCL_00004507.047.aec
Manufacturer	Filter Model	Filter Part Number	
Camfil	30/30 Dual 9	406331-005	


Clean Resistance Table			
cfm	m ³ /s	inWG	Pa
986	0.47	0.08	20
1476	0.70	0.16	40
1966	0.93	0.26	65
2462	1.16	0.39	97



App J Composite Minimum Particle Size Efficiency




ΔP (inWG)	Dust Fed (g)
0.26	0
0.26	30
0.46	75
0.65	150
0.85	180
1.00	200



ASHRAE® 52.2-2012 Test Results w/ Appendix J Results

Date:	01/19/2017			Test Number:		16206-012-KCL_00004507.047.aec							
Manufacturer				Filter Model						Filter Part Number			
Camfil				30/30 Dual 9						406331-005			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	2	2	6	13	26	36	46	68	84	93	96	97
	KCl Cond PSE	4	5	8	17	26	29	44	63	78	87	91	91
	1st Dust Load PSE	18	21	29	44	60	71	82	95	99	100	100	100
	2nd Dust Load PSE	23	30	41	58	75	82	91	98	100	100	100	100
	3rd Dust Load PSE	27	35	49	67	82	88	94	99	100	100	100	100
4th Dust Load PSE	30	39	56	73	87	91	96	99	100	100	100	100	
Composite Min PSE	2	2	6	13	26	29	44	63	78	87	91	91	

Appendix J Particle Size Efficiency




Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
303.0	1.51E+05	790	1.23E+08	
Large Particle Concentration (Particles ft ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)	Same duct?	
		Initial ΔP	Final ΔP	
30,000	142,546	0.26	0.26	No

ASHRAE® 52.2-2012 Test Results w/ Appendix J Results

Date:	01/19/2017			Test Number:			16206-012-KCL_00004507.047.aec					
Manufacturer				Filter Model						Filter Part Number		
Camfil				30/30 Dual 9						406331-005		
KCI Conditioning Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	2	2	6	13	26	36	46	68	84	93	96	97
1st KCI Cond PSE	2	4	7	15	23	30	44	64	81	88	92	93
2nd KCI Cond PSE	4	5	8	17	26	29	44	63	78	87	91	91
3rd KCI Cond PSE												
4th KCI Cond PSE												
5th KCI Cond PSE												
Final KCI Cond PSE	4	5	8	17	26	29	44	63	78	87	91	91

KCI Conditioning Particle Size Efficiency



ISO 16890-1:2016 - Air Filter Test Results Summary

Test Information

Report ID	Report Date	Test Requested by	Supervisor
USA-1585-4252R	7-Nov-2019	Manufacturer	Don Thornburg

Device Tested

Manufacturer	Model		Part Number	How Test Sample Obtained & Date	
Camfil USA	30/30 D9 2in		406331-005	Manufacturer Suplied	14-Aug-2017
Nom Size HxWxD (in)	Pleats/Pockets	Media Color	Media Charge		Media Adhesive
24x24x2	29	Green/White	None		None
Media Type		Media Area (ft ²)	Product Type		UL Rating
Dual Layer Polyester		17.2	Pleated panel		UL 900


Test Results Summary

Resistance to Airflow					Fractional Efficiency and ISO Rating				
Airflow (cfm)	Measured Resistance (inWG)	Met Published value	Rated Initial Resistance (inWG)		Product Literature listed ISO 16890 Rating	Met Published value	ISO 16890 Rating		
2001	0.32		0.30		ISO ePM10 55%		ISO ePM10 60%		
Arrestance:	Initial:	62%	Average:	93%	<i>ePM₁</i>	<i>ePM_{1,min}</i>	<i>ePM_{2,5}</i>	<i>ePM_{2,5,min}</i>	<i>ePM₁₀</i>
Rated Final Resistance (inWG)		0.85			13%	14%	24%	24%	61%
Test Dust Capacity (TDC) (g)		485							

Test Information and Included Reports

Test Type	Test ID	Test Date	Test Time	Test Operator
Initial per ISO 16890-2	USA-1585-4252	7-Nov-2019	1:15	A. Acain
Conditioned per ISO 16890-4	USA-1585-4256	8-Nov-2019	9:29	A. Acain
Dust Loaded per 16890-3	USA-1585-4271	14-Nov-2019	10:09	A. Acain

Fractional Efficiency by Particle Size



Approvals

	Certified Test Per ISO 16890-1:2016	Test Organization	Camfil USA 1 N. Corporate Dr. Riverdale, NJ 07457 (973) 616-7300
	<i>Don Thornburg, R&D Manager</i>		
	Electronic Signature, Original on file		

Note:

The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.

ISO 16890-1:2016 - Air Filter Test Results Details

Test Information


Report ID	Report Date	Test Organization	Supervisor
USA-1585-4252R	7-Nov-2019	Camfil USA	Don Thornburg

Clean Resistance Table at 1.2kg/m³

Test Airflow			Resistance	
% Rated	m ³ /s	cfm	Pa	inWG
25%	0.23	500	15	0.05
50%	0.47	1000	27	0.11
100%	0.95	2000	80	0.31
125%	1.17	2500	110	0.44

For complete Test Result Details and data, please review the individual test reports for ISO 16890-2, 16890-3, and 16890-4.


Resistance of Clean Device



Dust Captured Table

Resistance to Airflow		Dust Load (g)
Pa	inWG	
71	0.29	0
68	0.27	24
71	0.29	121
89	0.36	221
115	0.46	321
154	0.62	421
217	0.87	521
N/A	N/A	N/A


Resistance vs. Test Dust Captured



Arrestance Table

Arrestance (%)	Dust Load Increment (g)
62	12
86	73
93	171
93	271
96	371
#VALUE!	471
#VALUE!	N/A

Arrestance vs. Test Dust Captured



Note:

The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.

ISO 16890-1:2016 - Results Calculations

Report ID	Report Date	Test Organization	Supervisor
USA-1585-4252R	7-Nov-2019	Camfil USA	Don Thornburg

Fractional Efficiency Values							
i	d_i	d_{i+1}	d_m	$\Delta \ln d_i$	E_i	$E_{D,i}$	$E_{A,i}$
1	0.30	0.40	0.35	0.29	7%	8%	7%
2	0.40	0.55	0.47	0.32	13%	13%	13%
3	0.55	0.70	0.62	0.24	17%	18%	17%
4	0.70	1.00	0.84	0.36	20%	22%	21%
5	1.00	1.30	1.14	0.26	24%	27%	26%
6	1.30	1.60	1.44	0.21	33%	34%	34%
7	1.60	2.20	1.88	0.32	46%	48%	47%
8	2.20	3.00	2.57	0.31	64%	66%	65%
9	3.00	4.00	3.46	0.29	79%	81%	80%
10	4.00	5.50	4.69	0.32	86%	89%	87%
11	5.50	7.00	6.20	0.24	86%	91%	89%
12	7.00	10.00	8.37	0.36	85%	91%	88%

Symbols and Units	
d_i	Lower limit particle diameter in a size range i , μm
d_{i+1}	Upper limit particle diameter in a size range i , μm
d_m	Geometric mean diameter of a size range, μm
$\Delta \ln d_i$	Logarithmic width of a particle diameter size range i
E_i	Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, %
$E_{D,i}$	Fractional efficiency of particle size range i of the conditioned filter element, %
$E_{A,i}$	Average fractional efficiency of particle size range i , %

ISO 16890-1:2016 - Results Calculations

Report ID	Report Date	Test Organization	Supervisor
USA-1585-4252R	7-Nov-2019	Camfil USA	Don Thornburg

Calculation of PM Efficiencies										
i	d_m	$\Delta \ln d_i$	q_{3u} (Urban Distribution)	$q_{3u} * \Delta \ln d_i$	$E_{D,i} * q_{3u} * \Delta \ln d_i$	$E_{A,i} * q_{3u} * \Delta \ln d_i$	ePM _{1,min}	ePM ₁		
	μm	μm								
1	0.35	0.29	22.627%	0.065095	0.004933	0.004557				
2	0.47	0.32	19.891%	0.063343	0.008262	0.008235				
3	0.62	0.24	15.837%	0.038193	0.006746	0.006493				
4	0.84	0.36	11.522%	0.041097	0.009022	0.008630	14%	13%		
	Sums:			0.207728	0.028964	0.027915				
5	1.14	0.26	8.503%	0.022309	0.006039	0.005800	ePM _{2,5, min}	ePM _{2.5}		
6	1.44	0.21	7.618%	0.015817	0.005385	0.005378				
7	1.88	0.32	8.022%	0.025546	0.012182	0.012007				
8	2.57	0.31	9.984%	0.030966	0.020583	0.020128				
	Sums:			0.302366	0.073154	0.071227	24%	24%		
i	d_m	$\Delta \ln d_i$	q_{3r} (Rural Distribution)	$q_{3r} * \Delta \ln d_i$		$E_{A,i} * q_{3r} * \Delta \ln d_i$				
	μm	μm								
1	0.35	0.29	9.412%	0.027077		0.001895				
2	0.47	0.32	8.395%	0.026733		0.003475				
3	0.62	0.24	7.432%	0.017924		0.003047				
4	0.84	0.36	7.014%	0.025016		0.005253				
5	1.14	0.26	7.628%	0.020013		0.005203				
6	1.44	0.21	8.833%	0.018340		0.006236				
7	1.88	0.32	10.804%	0.034406		0.016171				
8	2.57	0.31	13.726%	0.042573		0.027672				
9	3.46	0.29	16.708%	0.048067		0.038454				
10	4.69	0.32	19.542%	0.062233		0.054143				
11	6.20	0.24	21.671%	0.052261		0.046513				
12	8.37	0.36	23.143%	0.082545		0.072639				
	Sums:			0.457189		0.280702	61%			