


ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description									
Manufacturer			Filter Model			Filter Part Number			
Camfil USA			OPDBMV11 24x24x2			855142-001			
Filter Type			Media Type		Media Color		Media Area (ft ²)		
Minipleat			Synthetic		White		54		
Nominal Size		Actual Size							
HxWxD		Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets		UL Rating		
24"x24"x4"		23 3/8	23 3/8	3 3/4	114		Yes		
ASHRAE 52.2-2017					ASHRAE 52.2-2017 w/App J				
Test Report:		200609_1834			Test Report:		200615_1847		
Time:	8:45:04	Date:	20/06/09		Time:	11:36:00	Date:	20/06/15	
Test Data		Test Results	Rated Values		Test Data		Test Results	Rated Values	
AirFlow (cfm)		2005	2000		AirFlow (cfm)		2002	2000	
Nominal Vel (fpm)		501	500		Nominal Vel (fpm)		501	500	
Initial ΔP (inWG)		0.41	0.46		Initial ΔP (inWG)		0.37	0.46	
MERV		12	11	@2005cfm	MERV-A		11A	11A	@2002cfm
E ₁ (0.3-1.0μm), (%)		57	≥ 20		E ₁ -A (0.3-1.0μm), (%)		37	≥ 20	
E ₂ (1.0-3.0μm), (%)		85	≥ 65		E ₂ -A (1.0-3.0μm), (%)		71	≥ 65	
E ₃ (3.0-10μm), (%)		97	≥ 85		E ₃ -A (3.0-10μm), (%)		95	≥ 85	
Final DP, (inWG)		1.0	1.0		Final DP, (inWG)		1.0	1.0	
Arrestance, (%)		99	95		Arrestance-A, (%)		98	95	
DHC, (g)		107			DHC-A, (g)		117		
Temp, (F)	74	Test Aerosol		KCL	Temp, (F)	74	Test Aerosol		KCL
RH, (%)	48	Loading Dust		ASHRAE	RH, (%)	49	Loading Dust		ASHRAE
 									
Certified Test Per ASHRAE 52.2-2017					Operator		Particle Counter		Model
Approval:	Don Thornburg, R&D Manager Electronic Signature, Original on file				AA		TSI		OPS-3330

ASHRAE® 52.2-2017 Test Results

Date:	20/06/09	Test Report:	200609_1834
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDBMV11 24x24x2	855142-001	


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
1015	0.48	0.152307	38
1508	0.71	0.265231	66
2005	0.95	0.411912	103
2490	1.18	0.577882	144


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.40	0
0.40	0
0.55	30
0.70	58
0.86	84
1.01	107

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	20/06/09			Test Report:			200609_1834					
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDBMV11 24x24x2					855142-001			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	46	59	64	67	77	84	85	94	96	98	98	98
Dust Cond PSE	39	64	72	79	84	88	91	95	97	98	98	99
1st Dust Load PSE	62	68	76	84	90	93	96	99	99	100	100	100
2nd Dust Load PSE	65	71	81	87	92	94	97	99	100	100	100	100
3rd Dust Load PSE	68	75	83	89	94	96	98	99	100	100	100	100
4th Dust Load PSE	66	74	82	89	94	96	98	99	100	100	100	100
Composite Min PSE	39	59	64	67	77	84	85	94	96	98	98	98

Particle Size Efficiency



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	20/06/15	Test Number:	200615_1847
Manufacturer	Filter Model		Filter Part Number
Camfil USA	OPDBMV11 24x24x2		855142-001


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
997	0.47	0.136896	34
1502	0.71	0.249867	62
2002	0.94	0.374398	93
2497	1.18	0.563228	140

Resistance of Clean Device




App J Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.37	0
0.37	0
0.54	49
0.69	81
0.85	102
1.01	117

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	20/06/15			Test Number:			200615_1847						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV11 24x24x2						855142-001			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	43	54	63	72	81	85	93	96	98	98	99	99
	KCl Cond PSE	23	30	41	52	60	65	74	85	92	95	97	97
	1st Dust Load PSE	37	47	59	70	79	84	91	97	99	100	100	100
	2nd Dust Load PSE	42	55	69	78	87	92	96	99	100	100	100	100
	3rd Dust Load PSE	48	61	73	84	90	93	97	99	100	100	100	100
4th Dust Load PSE	50	65	78	87	93	95	98	99	100	100	100	100	
Composite Min PSE	23	30	41	52	60	65	74	85	92	95	97	97	

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
15.0	4.74E+05	357	1.69E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)	Same duct?	
21	22,549	Initial ΔP	Final ΔP	No
		0.37	0.37	




Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	20/06/15			Test Number:			200615_1847						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV11 24x24x2						855142-001			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	43	54	63	72	81	85	93	96	98	98	99	99
	1st KCI Cond PSE	36	44	51	59	70	76	83	91	96	98	98	99
	2nd KCI Cond PSE	27	33	42	52	62	67	76	87	93	96	97	98
	3rd KCI Cond PSE												
	4th KCI Cond PSE												
5th KCI Cond PSE													
Final KCI Cond PSE	27	33	42	52	62	67	76	87	93	96	97	98	

KCI Conditioning Particle Size Efficiency



ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description									
Manufacturer		Filter Model			Filter Part Number				
Camfil USA		OPDBMV11 24x24x4			855143-001				
Filter Type		Media Type		Media Color		Media Area (ft ²)			
Mini pleat		Synthetic		White		77			
Nominal Size		Actual Size							
HxWxD		Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets		UL Rating		
24"x24"x4"		23 3/8	23 3/8	3 3/4	69		Yes		
ASHRAE 52.2-2017					ASHRAE 52.2-2017 w/App J				
Test Report:		191212_1617			Test Report:		200604_1727		
Time:	12:06:01	Date:	Dec 12, 2019		Time:	11:57:49	Date:	Jun 04, 2020	
Test Data		Test Results	Rated Values		Test Data		Test Results	Rated Values	
AirFlow (cfm)		1997	2000		AirFlow (cfm)		1995	2000	
Nominal Vel (fpm)		499	500		Nominal Vel (fpm)		499	500	
Initial ΔP (inWG)		0.40	0.37		Initial ΔP (inWG)		0.38	0.37	
MERV		13	11	@1997cfm	MERV-A		11A	11A	@1995cfm
E ₁ (0.3-1.0μm), (%)		70	≥ 20		E ₁ -A (0.3-1.0μm), (%)		28	≥ 20	
E ₂ (1.0-3.0μm), (%)		91	≥ 65		E ₂ -A (1.0-3.0μm), (%)		69	≥ 65	
E ₃ (3.0-10μm), (%)		98	≥ 85		E ₃ -A (3.0-10μm), (%)		95	≥ 85	
Final DP, (inWG)		1.5	1.0		Final DP, (inWG)		1.5	1.0	
Arrestance, (%)		98	93		Arrestance-A, (%)		98	95	
DHC, (g)		192			DHC-A, (g)		197		
Temp, (F)	75	Test Aerosol		KCL	Temp, (F)	73	Test Aerosol		KCL
RH, (%)	47	Loading Dust		ASHRAE	RH, (%)	50	Loading Dust		ASHRAE
 									
Certified Test Per ASHRAE 52.2-2017					Operator		Particle Counter		Model
Approval:	Don Thornburg, R&D Manager Electronic Signature, Original on file				AA		TSI		OPS-3330



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Dec 12, 2019	Test Report:	191212_1617
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDBMV11 24x24x4	855143-001	


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
1015	0.48	0.141456	35
1502	0.71	0.252371	63
1997	0.94	0.403472	100
2495	1.18	0.585517	146


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.41	0
0.45	11
0.72	86
0.98	135
1.25	167
1.51	192

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Dec 12, 2019			Test Report:		191212_1617						
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDBMV11 24x24x4					855143-001			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	59	67	73	80	87	89	92	96	98	98	98	99
Dust Cond PSE	65	73	78	84	91	93	96	98	100	100	100	100
1st Dust Load PSE	76	83	87	92	96	96	98	100	100	100	100	100
2nd Dust Load PSE	81	87	91	95	97	98	99	100	100	100	100	100
3rd Dust Load PSE	83	90	94	97	99	99	100	100	100	100	100	100
4th Dust Load PSE	86	92	95	97	99	99	100	100	100	100	100	100
Composite Min PSE	59	67	73	80	87	89	92	96	98	98	98	99



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	06/04/2020	Test Number:	200604_1727
Manufacturer	Filter Model		Filter Part Number
Camfil USA	OPDBMV11 24x24x4		855143-001


Clean Resistance Table

cfm	m^3/s	inWG	Pa
1013	0.48	0.11212	28
1495	0.71	0.234689	58
1995	0.94	0.382977	95
2507	1.18	0.567433	141

Resistance of Clean Device




App J Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.46	0
0.47	0
0.73	91
0.99	140
1.25	171
1.51	197

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	06/04/2020			Test Number:			200604_1727						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV11 24x24x4						855143-001			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	15	24	31	42	56	63	72	85	92	95	96	96
	KCl Cond PSE	16	27	34	47	60	69	78	89	96	98	99	100
	1st Dust Load PSE	40	53	61	70	82	88	93	97	99	100	100	100
	2nd Dust Load PSE	53	66	74	82	90	94	96	99	100	100	100	100
	3rd Dust Load PSE	52	68	77	89	95	97	98	100	100	100	100	100
	4th Dust Load PSE	68	80	87	92	97	98	99	100	100	100	100	100
	Composite Min PSE	15	24	31	42	56	63	72	85	92	95	96	96

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
2.0	5.85E+05	302	1.77E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)	Same duct?	
26	22,510	Initial ΔP	Final ΔP	No
		0.38	0.38	




Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	06/04/2020			Test Number:			200604_1727						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV11 24x24x4						855143-001			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	15	24	31	42	56	63	72	85	92	95	96	96
	1st KCI Cond PSE	39	50	58	67	76	81	87	93	96	98	98	99
	2nd KCI Cond PSE	15	27	34	46	59	67	76	87	94	97	98	99
	3rd KCI Cond PSE	14	27	34	45	58	67	76	87	95	98	99	99
	4th KCI Cond PSE												
	5th KCI Cond PSE												
	Final KCI Cond PSE	14	27	34	45	58	67	76	87	95	98	99	99

KCI Conditioning Particle Size Efficiency





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description

Manufacturer	Filter Model			Filter Part Number	
Camfil USA	OPDMV13 24x24x2			855142-011	
Filter Type	Media Type		Media Color	Media Area (ft ²)	
Minipleat	Synthetic		White	54	
Nominal Size	Actual Size				
HxWxD	Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets	UL Rating
24"x24"x2"	23 3/8	23 3/8	1 3/4	114	Yes

ASHRAE 52.2-2017

Test Report:	200325_1721		
Time:	1:04:21	Date:	Mar 25, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	1999	2000	
Nominal Vel (fpm)	500	500	
Initial ΔP (inWG)	0.50	0.50	
MERV	13	13	@1999cfm
E ₁ (0.3-1.0μm), (%)	67	≥ 50	
E ₂ (1.0-3.0μm), (%)	91	≥ 85	
E ₃ (3.0-10μm), (%)	97	≥ 90	
Final DP, (inWG)	1.0	1.0	
Arrestance, (%)	99	92	
DHC, (g)	76		
Temp, (F)	72	Test Aerosol	KCL
RH, (%)	49	Loading Dust	ASHRAE



ASHRAE 52.2-2017 w/App J

Test Report:	200529_1654		
Time:	3:27:32	Date:	May 29, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2006	2000	
Nominal Vel (fpm)	502	500	
Initial ΔP (inWG)	0.54	0.50	
MERV-A	12A	13A	@2006cfm
E ₁ -A (0.3-1.0μm), (%)	47	≥ 50	
E ₂ -A (1.0-3.0μm), (%)	85	≥ 85	
E ₃ -A (3.0-10μm), (%)	99	≥ 90	
Final DP, (inWG)	1.0	1.0	
Arrestance-A, (%)	99	92	
DHC-A, (g)	71		
Temp, (F)	77	Test Aerosol	KCL
RH, (%)	48	Loading Dust	ASHRAE

Certified Test Per ASHRAE 52.2-2017

Approval:	Don Thornburg, R&D Manager Electronic Signature, Original on file	Operator AA	Particle Counter TSI	Model OPS-3330
-----------	---	-----------------------	--------------------------------	--------------------------



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Mar 25, 2020	Test Report:	200325_1721
Manufacturer	Filter Model		Filter Part Number
Camfil USA	OPDMV13 24x24x2		855142-011


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
1011	0.48	0.145073	36
1506	0.71	0.311445	78
1999	0.94	0.495098	123
2497	1.18	0.69603	173


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.51	0
0.56	5
0.67	29
0.79	45
0.90	60
1.01	76

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Mar 25, 2020			Test Report:		200325_1721						
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDMV13 24x24x2					855142-011			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	53	65	72	80	87	89	92	95	96	97	97	98
Dust Cond PSE	65	74	81	87	92	95	97	99	100	100	100	100
1st Dust Load PSE	69	77	84	90	94	96	98	100	100	100	100	100
2nd Dust Load PSE	72	80	86	91	95	97	98	100	100	100	100	100
3rd Dust Load PSE	71	80	86	91	96	97	99	100	100	100	100	100
4th Dust Load PSE	71	81	87	92	96	98	99	100	100	100	100	100
Composite Min PSE	53	65	72	80	87	89	92	95	96	97	97	98



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/29/2020	Test Number:	200529_1654
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDMV13 24x24x2	855142-011	

Clean Resistance Table			
cfm	m^3/s	inWG	Pa
1000	0.47	0.174409	43
1503	0.71	0.345604	86
2006	0.95	0.543321	135
2486	1.17	0.771983	192



ΔP (inWG)	Dust Fed (g)
0.55	0
0.55	0
0.62	22
0.79	52
0.89	62
1.01	71






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/29/2020			Test Number:		200529_1654							
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDMV13 24x24x2						855142-011			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	60	70	77	84	90	92	95	97	98	99	99	99
	KCl Cond PSE	30	42	52	64	77	82	88	94	98	99	99	100
	1st Dust Load PSE	39	55	67	76	87	91	95	99	100	100	100	100
	2nd Dust Load PSE	42	58	71	81	89	93	96	99	100	100	100	100
	3rd Dust Load PSE	45	61	73	82	91	94	97	99	100	100	100	100
4th Dust Load PSE	45	62	73	82	91	95	97	99	100	100	100	100	
Composite Min PSE	30	42	52	64	77	82	88	94	98	99	99	99	

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
2.0	8.15E+05	420	3.42E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)		Same duct?
25	32,600	Initial ΔP	Final ΔP	No
		0.53	0.54	




Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/29/2020			Test Number:		200529_1654							
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDMV13 24x24x2						855142-011			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	60	70	77	84	90	92	95	97	98	99	99	99	
1st KCI Cond PSE	32	48	61	73	82	87	92	97	99	100	100	100	
2nd KCI Cond PSE	30	42	52	64	76	81	87	94	98	99	99	99	
3rd KCI Cond PSE													
4th KCI Cond PSE													
5th KCI Cond PSE													
Final KCI Cond PSE	30	42	52	64	76	81	87	94	98	99	99	99	

KCI Conditioning Particle Size Efficiency





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description

Manufacturer	Filter Model			Filter Part Number	
Camfil USA	OPDBMV13 24x24x4			855143-011	
Filter Type	Media Type		Media Color	Media Area (ft ²)	
Mini pleat	Synthetic		White	77	
Nominal Size	Actual Size				
HxWxD	Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets	UL Rating
24"x24"x4"	23 3/8	23 3/8	3 3/4	69	Yes

ASHRAE 52.2-2017

Test Report:	200221_1718		
Time:	11:54:57	Date:	Feb 21, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2002	2000	
Nominal Vel (fpm)	501	500	
Initial ΔP (inWG)	0.48	0.46	
MERV	13	13	@2002cfm
E ₁ (0.3-1.0μm), (%)	71	≥ 50	
E ₂ (1.0-3.0μm), (%)	92	≥ 85	
E ₃ (3.0-10μm), (%)	98	≥ 90	
Final DP, (inWG)	1.5	1.0	
Arrestance, (%)	99	98	
DHC, (g)	162		
Temp, (F)	73	Test Aerosol	KCL
RH, (%)	24	Loading Dust	ASHRAE

ASHRAE 52.2-2017 w/App J

Test Report:	200528_1722		
Time:	11:40:39	Date:	May 28, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2000	2000	
Nominal Vel (fpm)	500	500	
Initial ΔP (inWG)	0.52	0.46	
MERV-A	13A	13A	@2000cfm
E ₁ -A (0.3-1.0μm), (%)	54	≥ 50	
E ₂ -A (1.0-3.0μm), (%)	89	≥ 85	
E ₃ -A (3.0-10μm), (%)	98	≥ 90	
Final DP, (inWG)	1.5	1.0	
Arrestance-A, (%)	99	95	
DHC-A, (g)	157		
Temp, (F)	74	Test Aerosol	KCL
RH, (%)	50	Loading Dust	ASHRAE



Certified Test Per ASHRAE 52.2-2017

Approval:	<i>Don Thornburg, R&D Manager</i> Electronic Signature, Original on file	Operator	Particle Counter	Model
		EO	TSI	OPS-3330



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Feb 21, 2020	Test Report:	200221_1718
Manufacturer	Filter Model		Filter Part Number
Camfil USA	OPDBMV13 24x24x4		855143-011


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
996	0.47	0.141858	35
1512	0.71	0.30381	76
2002	0.94	0.481434	120
2489	1.17	0.725366	181


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.50	0
0.51	15
0.76	60
1.01	105
1.26	139
1.51	162

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Feb 21, 2020			Test Report:		200221_1718						
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDBMV13 24x24x4					855143-011			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	58	68	75	82	88	90	93	95	97	98	98	98
Dust Cond PSE	69	80	85	91	95	97	98	99	100	100	100	100
1st Dust Load PSE	75	84	89	93	96	98	99	100	100	100	100	100
2nd Dust Load PSE	79	87	91	95	98	98	99	100	100	100	100	100
3rd Dust Load PSE	81	88	92	96	98	99	99	100	100	100	100	100
4th Dust Load PSE	80	88	92	96	98	99	99	100	100	100	100	100
Composite Min PSE	58	68	75	82	88	90	93	95	97	98	98	98



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/28/2020	Test Number:	200528_1722
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDBMV13 24x24x4	855143-011	

Clean Resistance Table			
cfm	m^3/s	inWG	Pa
988	0.47	0.155924	39
1500	0.71	0.324707	81
2000	0.94	0.518808	129
2496	1.18	0.764347	190



ΔP (inWG)	Dust Fed (g)
0.53	0
0.53	0
0.75	34
0.96	69
1.27	114
1.50	157






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/28/2020			Test Number:		200528_1722							
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV13 24x24x4						855143-011			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	55	66	73	81	87	89	92	95	97	98	98	98
	KCl Cond PSE	39	50	60	69	82	87	92	96	99	99	100	100
	1st Dust Load PSE	50	63	72	81	88	92	95	98	100	100	100	100
	2nd Dust Load PSE	58	70	77	84	91	93	96	99	100	100	100	100
	3rd Dust Load PSE	63	74	81	88	93	95	97	99	100	100	100	100
4th Dust Load PSE	58	71	80	92	96	97	99	100	100	100	100	100	
Composite Min PSE	39	50	60	69	82	87	92	95	97	98	98	98	

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
2.0	8.01E+05	632	5.06E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)		Same duct?
11	75,566	Initial ΔP	Final ΔP	
		0.51	0.51	no




Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/28/2020			Test Number:			200528_1722						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV13 24x24x4						855143-011			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	55	66	73	81	87	89	92	95	97	98	98	98
	1st KCI Cond PSE	47	59	68	77	85	88	92	96	98	99	99	99
	2nd KCI Cond PSE	43	55	65	75	84	87	92	96	98	99	100	99
	3rd KCI Cond PSE	40	53	63	74	83	87	92	96	99	100	100	100
	4th KCI Cond PSE	37	51	63	74	83	87	92	96	99	100	100	100
5th KCI Cond PSE													
Final KCI Cond PSE	37	51	63	74	83	87	92	96	99	100	100	100	

KCI Conditioning Particle Size Efficiency





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description

Manufacturer	Filter Model			Filter Part Number	
Camfil USA	OPDMV15 24x24x2			855142031	
Filter Type	Media Type		Media Color	Media Area (ft ²)	
Mini pleat	Synthetic		White	54	
Nominal Size	Actual Size				
HxWxD	Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets	UL Rating
24"x24"x4"	23 3/8	23 3/8	1 3/4	114	Yes

ASHRAE 52.2-2017

Test Report:	200324_1725		
Time:	10:58:00	Date:	Mar 24, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2004	2000	
Nominal Vel (fpm)	501	500	
Initial ΔP (inWG)	0.53	0.60	
MERV	15	15	@2004cfm
E ₁ (0.3-1.0μm), (%)	86	≥ 85	
E ₂ (1.0-3.0μm), (%)	97	≥ 90	
E ₃ (3.0-10μm), (%)	100	≥ 95	
Final DP, (inWG)	1.0	1.0	
Arrestance, (%)	99	95	
DHC, (g)	51		
Temp, (F)	72	Test Aerosol	KCL
RH, (%)	48	Loading Dust	ASHRAE



ASHRAE 52.2-2017 w/App J

Test Report:	200326_1765		
Time:	10:54:10	Date:	Mar 26, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2010	2000	
Nominal Vel (fpm)	503	500	
Initial ΔP (inWG)	0.55	0.60	
MERV-A	14A	15A	@2010cfm
E ₁ -A (0.3-1.0μm), (%)	76	≥ 85	
E ₂ -A (1.0-3.0μm), (%)	95	≥ 90	
E ₃ -A (3.0-10μm), (%)	99	≥ 95	
Final DP, (inWG)	1.0	1.0	
Arrestance-A, (%)	99	98	
DHC-A, (g)	64		
Temp, (F)	72	Test Aerosol	KCL
RH, (%)	49	Loading Dust	ASHRAE

Certified Test Per ASHRAE 52.2-2017

Approval:	<i>Don Thornburg, R&D Manager</i> Electronic Signature, Original on file	Operator AA	Particle Counter TSI	Model OPS-3330
-----------	---	-----------------------	--------------------------------	--------------------------



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Mar 24, 2020	Test Report:	200324_1725
Manufacturer	Filter Model		Filter Part Number
Camfil USA	OPDMV15 24x24x2		855142031


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
1003	0.47	0.20254	50
1508	0.71	0.360875	90
2004	0.95	0.533677	133
2485	1.17	0.726974	181


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.55	0
0.59	14
0.70	29
0.80	38
0.90	46
1.01	51

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Mar 24, 2020			Test Report:		200324_1725						
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDMV15 24x24x2					855142031			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	77	85	89	93	96	97	98	99	99	100	100	100
Dust Cond PSE	82	89	93	96	98	99	99	100	100	100	100	100
1st Dust Load PSE	85	91	95	97	98	99	99	100	100	100	100	100
2nd Dust Load PSE	87	93	96	98	99	99	100	100	100	100	100	100
3rd Dust Load PSE	88	94	96	98	99	99	100	100	100	100	100	100
4th Dust Load PSE	89	94	97	98	99	99	100	100	100	100	100	100
Composite Min PSE	77	85	89	93	96	97	98	99	99	100	100	100



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	03/26/2020	Test Number:	200326_1765
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDMV15 24x24x2	855142031	

Clean Resistance Table			
cfm	m^3/s	inWG	Pa
988	0.47	0.21339	53
1506	0.71	0.373333	93
2010	0.95	0.545331	136
2499	1.18	0.774394	193



ΔP (inWG)	Dust Fed (g)
0.56	0
0.56	0
0.70	19
0.81	36
0.91	52
1.01	64






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	03/26/2020			Test Number:			200326_1765						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDMV15 24x24x2						855142031			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	80	88	92	95	97	98	98	99	99	100	100	100
	KCl Cond PSE	63	74	81	85	92	93	96	98	98	99	100	100
	1st Dust Load PSE	73	81	86	91	95	97	98	99	100	100	100	100
	2nd Dust Load PSE	72	81	87	92	96	97	98	99	100	100	100	100
	3rd Dust Load PSE	73	82	88	93	96	97	99	99	100	100	100	100
4th Dust Load PSE	77	85	90	94	97	98	99	99	100	100	100	100	
Composite Min PSE	63	74	81	85	92	93	96	98	98	99	100	100	

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
1.7	5.01E+05	406	2.03E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)		Same duct?
22	22,782	Initial ΔP	Final ΔP	22.00
		0.53	0.55	




Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	03/26/2020			Test Number:			200326_1765						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDMV15 24x24x2						855142031			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	80	88	92	95	97	98	98	99	99	100	100	100
	1st KCI Cond PSE	69	78	84	89	94	95	97	99	99	100	100	100
	2nd KCI Cond PSE	63	74	81	85	92	93	96	98	98	99	100	100
	3rd KCI Cond PSE												
	4th KCI Cond PSE												
5th KCI Cond PSE													
Final KCI Cond PSE	63	74	81	85	92	93	96	98	98	99	100	100	

KCI Conditioning Particle Size Efficiency





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE 52.2-2017 Test Results w/Appendix J Results

Filter Description

Manufacturer	Filter Model			Filter Part Number	
Camfil USA	OPDBMV15 24x24x4			855143-031	
Filter Type	Media Type		Media Color	Media Area (ft ²)	
Minipleat	Synthetic		White	77	
Nominal Size	Actual Size				
HxWxD	Hgt (in)	Wid (in)	Dep (in)	Pleats/Pockets	UL Rating
24"x24"x4"	23 3/8	23 3/8	3 3/4	69	Yes

ASHRAE 52.2-2017

Test Report:	191211_1616		
Time:	12:51:07	Date:	Dec 19, 2019
Test Data	Test Results	Rated Values	
AirFlow (cfm)	2010	2000	
Nominal Vel (fpm)	503	500	
Initial ΔP (inWG)	0.51	0.50	
MERV	15	15	@2010cfm
E ₁ (0.3-1.0μm), (%)	92	≥ 85	
E ₂ (1.0-3.0μm), (%)	98	≥ 90	
E ₃ (3.0-10μm), (%)	100	≥ 95	
Final DP, (inWG)	1.5	1.0	
Arrestance, (%)	100	98	
DHC, (g)	169		
Temp, (F)	72	Test Aerosol	KCL
RH, (%)	49	Loading Dust	ASHRAE

ASHRAE 52.2-2017 w/App J

Test Report:	200521_1726		
Time:	11:27:27	Date:	May 21, 2020
Test Data	Test Results	Rated Values	
AirFlow (cfm)	1993	2000	
Nominal Vel (fpm)	498	500	
Initial ΔP (inWG)	0.51	0.50	
MERV-A	14A	15A	@1993cfm
E ₁ -A (0.3-1.0μm), (%)	80	≥ 85	
E ₂ -A (1.0-3.0μm), (%)	98	≥ 90	
E ₃ -A (3.0-10μm), (%)	100	≥ 95	
Final DP, (inWG)	1.5	1.0	
Arrestance-A, (%)	99	98	
DHC-A, (g)	150		
Temp, (F)	75	Test Aerosol	KCL
RH, (%)	48	Loading Dust	ASHRAE



Certified Test Per ASHRAE 52.2-2017

Approval:	<i>Don Thornburg, R&D Manager</i> Electronic Signature, Original on file	Operator	Particle Counter	Model
		EO	TSI	OPS-3330



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Dec 19, 2019	Test Report:	191211_1616
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDBMV15 24x24x4	855143-031	


Clean Resistance Table

cfm	m ³ /s	inWG	Pa
1005	0.47	0.185662	46
1505	0.71	0.336763	84
2010	0.95	0.513985	128
2506	1.18	0.729787	182


#####

248.8454

Resistance of Clean Device




Composite Minimum Particle Size Efficiency



ΔP (inWG)	Dust Fed (g)
0.51	0
0.55	15
0.80	76
1.03	115
1.27	145
1.51	169

Resistance (inWG) vs. Dust Fed (g)






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results

Date:	Dec 19, 2019			Test Report:		191211_1616						
Manufacturer				Filter Model					Filter Part Number			
Camfil USA				OPDBMV15 24x24x4					855143-031			
Efficiency Data Table												
	1	2	3	4	5	6	7	8	9	10	11	12
Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
Initial PSE	86	91	94	96	98	98	99	99	100	100	100	100
Dust Cond PSE	88	93	95	97	98	99	99	100	100	100	100	100
1st Dust Load PSE	92	95	97	98	99	99	100	100	100	100	100	100
2nd Dust Load PSE	94	97	98	99	100	100	100	100	100	100	100	100
3rd Dust Load PSE	95	97	99	99	100	100	100	100	100	100	100	100
4th Dust Load PSE	95	97	99	99	100	100	100	100	100	100	100	100
Composite Min PSE	86	91	94	96	98	98	99	99	100	100	100	100



All testing is performed in compliance with the latest revision of ASHRAE Standard 52.2 in a state-of-the-art laboratory facility located at the Camfil USA headquarters in Riverdale, NJ. Test Reports without DHC values show efficiency only and the associated MERV value is a estimated value based on the single efficiency data shown. For more information, contact your local Camfil representative or distributor.

This report and the data contained herein is the property of Camfil and is confidential between Camfil and the recipient only. It may only be reused or reprinted or distributed with the written permission of Camfil.





Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300


ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/21/2020	Test Number:	200521_1726
Manufacturer	Filter Model	Filter Part Number	
Camfil USA	OPDBMV15 24x24x4	855143-031	

Clean Resistance Table			
cfm	m^3/s	inWG	Pa
1004	0.47	0.185662	46
1500	0.71	0.336763	84
1993	0.94	0.513985	128
2501	1.18	0.729787	182



ΔP (inWG)	Dust Fed (g)
0.51	0
0.51	0
0.76	47
1.01	92
1.25	124
1.51	150






Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/21/2020			Test Number:			200521_1726						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV15 24x24x4						855143-031			
App J Efficiency Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	80	88	91	95	97	98	98	99	100	100	100	100
	KCl Cond PSE	64	76	84	94	97	98	99	99	99	100	100	100
	1st Dust Load PSE	68	79	86	95	98	99	100	100	100	100	100	100
	2nd Dust Load PSE	73	83	89	97	99	99	100	100	100	100	100	100
	3rd Dust Load PSE	76	86	92	98	99	100	100	100	100	100	100	100
4th Dust Load PSE	81	90	93	97	99	100	100	100	100	100	100	100	
Composite Min PSE	64	76	84	94	97	98	98	99	99	100	100	100	

Appendix J Particle Size Efficiency



Bkg Concentration (particles/cm ³)	Avg Cond Aerosol Conc (particles/cm ³)	Cumulative Cond Duration (minutes)	Cumulative Cond CT (particles-min/cm ³)	
1.5	5.05E+05	725	3.66E+08	
Large Particle Concentration (Particles/cm ³)	Ratio Small to Large (>20,000)	Conditioning ΔP (inWG)		Same duct?
2	280,556	Initial ΔP	Final ΔP	
		0.51	0.51	No



Camfil USA
1 North Corporate Drive
Riverdale, NJ 07457
(973) 616-7300

ASHRAE® 52.2-2017 Test Results w/ Appendix J Results

Date:	05/21/2020			Test Number:			200521_1726						
Manufacturer				Filter Model						Filter Part Number			
Camfil USA				OPDBMV15 24x24x4						855143-031			
KCI Conditioning Data Table													
	1	2	3	4	5	6	7	8	9	10	11	12	
	Minimum Dia (µm)	0.3	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0
	Maximum Dia (µm)	0.4	0.55	0.7	1.0	1.3	1.6	2.2	3.0	4.0	5.5	7.0	10.0
	Geometric Mean (µm)	0.35	0.47	0.62	0.84	1.14	1.44	1.88	2.57	3.46	4.69	6.20	8.37
	Initial PSE	80	88	91	95	97	98	98	99	100	100	100	100
	1st KCI Cond PSE	77	85	90	94	97	98	99	100	100	100	100	100
	2nd KCI Cond PSE	73	82	88	93	96	98	98	99	100	100	100	100
	3rd KCI Cond PSE	64	76	84	94	97	98	99	100	100	100	100	100
	4th KCI Cond PSE												
5th KCI Cond PSE													
Final KCI Cond PSE	64	76	84	94	97	98	99	100	100	100	100	100	

KCI Conditioning Particle Size Efficiency

